














<p>A ON Delay</p>  <p>Supply Voltage (U)</p> <p>Relay Output (R)</p> <p>$T = \text{set time}$</p>	<p>Ai Delay on Break with totalise</p>  <p>Supply Voltage (U)</p> <p>Control Contact (Y1)</p> <p>Relay Output (R)</p> <p>$t_1 + t_2 = T$</p> <p>$T = \text{set time}$</p>
<p>B Interval</p>  <p>Supply Voltage (U)</p> <p>Relay Output (R)</p> <p>$T = \text{set time}$</p>	<p>Bi Interval with Totalise</p>  <p>Supply Voltage (U)</p> <p>Control Contact (Y1)</p> <p>Relay Output (R)</p> <p>$t_1 + t_2 = T$</p> <p>$T = \text{set time}$</p>
<p>C Repeat Cycle Equal (OFF 1" with Y contact)</p>  <p>Supply Voltage (U)</p> <p>Control Contact (Y1)</p> <p>Relay Output (R)</p> <p>$T = \text{set time}$</p>	<p>Ci Repeat Cycle Equal (ON 1")</p>  <p>Supply Voltage (U)</p> <p>Relay Output (R)</p> <p>$T = \text{set time}$</p>
<p>Note : 600XU : With Y contact ; 600U-2 : Without Y contact</p>	
<p>D Pulse Output</p>  <p>Supply Voltage (U)</p> <p>Relay Output (R)</p> <p>$P = 500 \text{ msec}$</p> <p>$T = \text{set time}$</p>	<p>E Delay on Break</p>  <p>Supply Voltage (U)</p> <p>Control Contact (Y1)</p> <p>Relay Output (R)</p> <p>$T = \text{set time}$</p>
<p>F Delay on make / Break</p>  <p>Supply Voltage (U)</p> <p>Control Contact (Y1)</p> <p>Relay Output (R)</p> <p>$T = \text{set time}$</p>	<p>H Interval after Break</p>  <p>Supply Voltage (U)</p> <p>Control Contact (Y1)</p> <p>Relay Output (R)</p> <p>$T = \text{set time}$</p>
<p>I Single Shot</p>  <p>Supply Voltage (U)</p> <p>Control Contact (Y1)</p> <p>Relay Output (R)</p> <p>$T = \text{set time}$</p>	<p>J Retriggerable Single Shot</p>  <p>Supply Voltage (U)</p> <p>Control Contact (Y1)</p> <p>Relay Output (R)</p> <p>t_a</p> <p>$T = \text{set time}$</p> <p>$t_a < T$</p>
<p>K Latching Relay</p>  <p>Supply Voltage (U)</p> <p>Control Contact (Y1)</p> <p>Relay Output (R)</p>	<p>Note : For 600U-2, only A, B, D, C & Ci modes are applicable.</p> <p>Selec Controls Pvt. Ltd.</p> <p>(Specifications are subject to change as development is a continuous process)</p> <p>Telephone : +91-22-40394200 / 40394202</p> <p>Fax : +91-22-28471733 Toll free : 1800 227 353</p> <p>Website : www.selec.com E- mail : sales@selec.com.</p> <p>Operating / 1103 / 600XU/600U-2 / OP299-V01 (Page 1 of 1)</p>